

10 Accessories

10.1 Ventable dummy coupling incl. mounted aluminium disc

The size of the air passage (ventilation cross section) complies with ÖNORM M7137 (section 4.2.1).

The mounted aluminium disc can be removed depending on the requirements and installation criteria. Thus, the dummy coupling can be used both in indoor (sealed) and outdoor areas (ventable).



| Item No. | Type | Dimension [mm] | Air passage [cm ²] | kg/pcs. | Drawing No. |
|----------|-------|----------------|--------------------------------|---------|--------------------|
| 15706 | Storz | A-110 | 30 | 1,4 | Z15706.02-17-01-DE |



| Item No. | Type | Dimension [mm] | Air passage [cm ²] | kg/pcs. | Drawing No. |
|----------|-----------|----------------|--------------------------------|---------|--------------------|
| 15649 | Guillemin | 100 | 30 | 1,5 | Z15649.02-17-01-DE |



| Item No. | Type | Dimension [mm] | Air passage [cm ²] | kg/pcs. | Drawing No. |
|----------|--------|----------------|--------------------------------|---------|--------------------|
| 14412 | Kamlok | 100 | 30 | 1,4 | Z14412.01-17-01-DE |